



CROSS SECTION

SECTION A - A

TABLE 1: ELECTRICAL REQUIREMENTS

TREATMENT PLANT COMPRESSOR	E60N
MOTOR FULL LOAD AMPS	Delta Model 06 4.8
MEASURED OPERATING WATTS	373
ELECTRICAL REQUIREMENTS	115 volt- single phase

TABLE 2: ECOPOD SPECIFICATIONS

TREATMENT PLANT	E60N
TREATMENT CAPACITY (GPD)	600
MIN. PRIMARY TANK VOLUME (GAL.)	600
REACTOR TANK VOLUME (GAL.)	916
MEDIA SIZE	6" X 2" X 2"
AIR REQUIREMENTS	14.4 CFM

NOTES

1. INSTALL TANK PER PRECASTER INSTRUCTIONS.
2. IF PRECAST DIMENSIONS ARE OUTSIDE THE MINIMUM DIMENSIONS, CONTACT DELTA FOR REVIEW.
3. FOR DESIGNS WITH TREATMENT CAPACITIES GREATER THAN 1,500 GPD, CONTACT DELTA FOR REVIEW.
4. OPTIONAL SCHEDULE 40 PVC INSERT INSTALLED TO RAISE ECOPOD TO INLET AND OUTLET HEIGHT REQUIREMENTS.

NO.	DATE	INITIALS	PROJECT NO.
C	04/25/22	E AV	19A
D	05/02/22	KJ	DATE
E	05/25/22	KJ	11/17/2021
			DESIGNED BY
			CSK
			DRAWING NO.
			C0.1
			AOB
			SHEET NO.
			01 of 01

DELTA ECOPOD E60-NIM
INFILTRATOR IM-1060 SEPTIC TANK

GENERAL ARRANGEMENT

delta
An Infiltrator Tank by Delta Systems

Delta Treatment Systems, LLC

Copyright © 2021 Delta Treatment Systems, LLC. All rights reserved. This information is confidential and is the property of Delta Treatment Systems, LLC. No part of this drawing shall be reproduced, distributed, disclosed, or used by any person or organization in any form or by any means, electronic or mechanical, including photocopying, recording, or by any information storage and retrieval system, without the prior written permission of Delta Treatment Systems, LLC. This information is for budgetary or preliminary use only and interpretation of this information and determining the applicability to a specific project is at the sole discretion of the user and/or the engineer of record.