



CROSS SECTION

SIDE VIEW

TABLE 3: ENVIRO-AIRE SPECIFICATIONS

TREATMENT PLANT	TREATMENT CAPACITY (GPD)	TOTAL VOLUME (GAL)	PRIMARY VOLUME (GAL)	AERATION VOLUME (GAL)	CLARIFIER VOLUME (GAL)	BOD LOADING (LBS/DAY)
EA75	750	1,113	346	584	186	1.25

REV. DATE	INITIALS	PROJECT NO.	
A. 7/26/2022	KJ	IM-1530	01 of 01
		HORIZ. SCALE	
		VERT. SCALE	
		DRAWN BY	
		DESIGNED BY	
		SHEET NO.	
		DTS	
		DRAWING NO.	
		J.K.	
		N/A	
		IM-1530 WITH ENVIRO-AIRE EA75	
		CROSS SECTION AND SIDE VIEW	
		9125 COLLETT DRIVE, ALHAMBRA, CA 91803 (800) 219-9185	
		<small> COPYRIGHT © 2022 DELTA TREATMENT SYSTEMS, LLC (DTS). INFORMATION CONTAINED HEREIN IS CONFIDENTIAL AND IS THE PROPERTY OF DTS. NO PART OF THIS DRAWING SHALL BE REPRODUCED, DISTRIBUTED, USED, COPIED, OR USED BY ANY PERSON OR ORGANIZATION IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF DTS. THIS DRAWING IS FOR BUDGETARY OR PRELIMINARY USE ONLY. USE AND INTERPRETATION OF THIS INFORMATION AND DETERMINING THE APPLICABILITY TO A SPECIFIC PROJECT IS AT THE SOLE DISCRETION OF THE USER AND/OR THE ENGINEER OF RECORD. </small>	